EMS FireCell

How to wire a Hardwired Weatherproof Call Point to a FireCell Wireless I/O Unit

FireCell Wireless I/O Unit

ANTENNA
KEEP CABLES AWAY FROM THIS AREA

012ABC

RELAY ON   RELAY ON

0 1
1
2
4
8
16
32
64
F-SAFE

LED
ENABLE

CLOSED

INPUT 1 INPUT 2   EXPAN1   EXPAN2   OUTPUT 1   OUTPUT

IP- IP+ IP- IP+ 3VDC SET RST 3VDC SET RST N/O COM N/C N/O COM N/C

Hardwired Weatherproof Call Point

5 6 7 8

4k7   20k

KAC ALARM COMPANY LIMITED
WCP3A-R000SF-K01S-01
FOR WIRING SEE D 904 (WCP3A)
EN54-11 TPE A, OUTDOOR USE
Made in the UK
1521
5225894   1 2   3 4   5 6   7 8   0832-CPD-0659

LPCB

1 2 3 4   5 6 7 8

INPUT 1   INPUT 2

IP-   IP+   IP-   IP+   3V

Note: Maximum Cable Length of 10m, Using Fire Rated Cable