

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00028

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): FireCell Radio Hub Range
(refer to attached appendix for details and conditions)

**Placed on the market
under the name or trade mark of:** EMS Security Group Limited
Technology House, Sea Street
Herne Bay, Kent, CT6 8JZ
United Kingdom

**and produced in the
manufacturing plant(s):** EMS Security Group Limited (SG- 15557)
Technology House, Sea Street
Herne Bay, Kent, CT6 8JZ
United Kingdom

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-25:2008+AC:2012
EN 54-18:2005+AC:2007

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00028** on **2015-02-02** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body
0905

Certification Manager: Dipl.-Ing. Roland Heine

Date Issue: 2020-07-22

Issue: 1

Signature:



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00028

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00028

The details and conditions of use for the FireCell Radio Hub Range, placed on the market under the name or trade mark of:

EMS Security Group Limited
Technology House, Sea Street
Herne Bay, Kent, CT6 8JZ
United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN 54-25:2008+AC:2012 and EN 54-18:2005+AC:2007.

Model	Manufacturing Location	Description
FCX-500-004	SG-15557	Radio Hub (Four Loop Integral Aerial) (4 x FC-868-D00 aerials supplied)
FCX-500-444	SG-15557	Radio Hub (Four Loop SMA Connectors) (4 x FC-868-D00 aerials supplied)

Bases:

None

Conditions of use:

Suitable for indoor applications only

General Notes:

1. Evaluated under Intertek project number 101748353.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.
3. The radio link functionality is not included within the scope of approval.

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.